



Life Science Laboratories, Inc.

Date Printed: 11/21/16

Laboratory Analysis Report Prepared For Hammondsport Central School

LSL Project ID: 1616376

Hammondsport Central School
8272 Main Street
Hammondsport, NY 14840

Phone: (607) 569-5200
FAX: (607) 569-5212

A copy of this report was sent to:

Hornell DOH

Sample ID: Hammondsport Central School

LSL Sample ID: 1616376-001

Location: Lead Study

Receive Date/Time: 10/04/16 7:30

Sampled: 09/30/16 6:00

Project Rec'd by: jms01

Sampled By: MM

Matrix: PWS

| Analytical Method | Prep Method | Prep Date | Analysis Date & Time | Analyst Initials |
|-------------------|--------------|-----------|----------------------|------------------|
| Analyte | Result Units | | | |

(1) Lead Study

Number of Samples

83

MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248
PA DEP #68-2556

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 728-3320
Fax (585) 728-2711
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by: _____

Date: _____

11/25/16

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-1
Lab ID: K1610283-001A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.10 * | mg/L | 10/27/16 19:33 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-2
Lab ID: K1610283-002A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.052 * | mg/L | 10/27/16 19:36 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-3
Lab ID: K1610283-003A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0086 | mg/L | 10/27/16 19:40 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-4

Lab ID: K1610283-004A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.015 * | mg/L | 10/27/16 19:44 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-5

Lab ID: K1610283-005A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.024 * | mg/L | 10/27/16 19:55 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-6
Lab ID: K1610283-006A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.015 * | mg/L | 10/27/16 19:59 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - B Analyte detected in the associated Method Blank
 - E Value exceeds the instrument calibration range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below the PQL
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - P Prim./Conf. column %D or RPD exceeds limit
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-7
Lab ID: K1610283-007A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0093 | mg/L | 10/27/16 20:03 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-8
Lab ID: K1610283-008A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0093 | mg/L | 10/27/16 20:06 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-9
Lab ID: K1610283-009A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.038 * | mg/L | 10/27/16 20:10 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-10
Lab ID: K1610283-010A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0015 | mg/L | 10/27/16 15:09 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-11
Lab ID: K1610283-011A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0081 | mg/L | 11/17/16 10:54 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-12
Lab ID: K1610283-012A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.046 * | mg/L | 10/27/16 15:16 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-13
Lab ID: K1610283-013A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.014 | mg/L | 10/27/16 15:22 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-14
Lab ID: K1610283-014A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0075 | mg/L | 10/27/16 15:24 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-15
Lab ID: K1610283-015A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.020 * | mg/L | 10/27/16 15:25 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-16
Lab ID: K1610283-016A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0091 | mg/L | 10/27/16 15:27 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-17
Lab ID: K1610283-017A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.015 | mg/L | 10/27/16 15:29 |

Qualifiers: * Value may exceed the Acceptable Level
 E Value exceeds the instrument calibration range
 J Analyte detected below the PQL
 P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Practical Quantitation Limit (PQL)
 S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-18
Lab ID: K1610283-018A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.058 * | mg/L | 10/27/16 15:31 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-19
Lab ID: K1610283-019A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.085 * | mg/L | 10/27/16 15:33 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-20
Lab ID: K1610283-020A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0058 | mg/L | 10/27/16 15:35 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-21
Lab ID: K1610283-021A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0069 | mg/L | 10/27/16 15:37 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-22
Lab ID: K1610283-022A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0069 | mg/L | 10/27/16 15:39 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-23
Lab ID: K1610283-023A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | < 0.0010 | mg/L | 10/27/16 15:44 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-24
Lab ID: K1610283-024A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.029 * | mg/L | 10/27/16 15:46 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-25
Lab ID: K1610283-025A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0019 | mg/L | 10/27/16 15:48 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-26
Lab ID: K1610283-026A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | < 0.0010 | mg/L | 10/27/16 15:50 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-27
Lab ID: K1610283-027A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | < 0.0010 | mg/L | 10/27/16 15:52 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-28
Lab ID: K1610283-028A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | < 0.0010 | mg/L | 10/27/16 15:54 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-29

Lab ID: K1610283-029A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0063 | mg/L | 10/27/16 15:56 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-30
Lab ID: K1610283-030A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0050 | mg/L | 10/27/16 15:57 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-31
Lab ID: K1610283-031A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.010 | mg/L | 10/27/16 16:09 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-32
Lab ID: K1610283-032A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | < 0.0010 | mg/L | 10/27/16 16:11 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-33
Lab ID: K1610283-033A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0054 | mg/L | 10/27/16 16:13 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-34
Lab ID: K1610283-034A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0076 | mg/L | 10/27/16 16:15 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-35
Lab ID: K1610283-035A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.021 * | mg/L | 10/27/16 16:17 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-36
Lab ID: K1610283-036A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.017 * | mg/L | 10/27/16 16:19 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-37
Lab ID: K1610283-037A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.026 * | mg/L | 10/27/16 16:21 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-38
Lab ID: K1610283-038A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.015 * | mg/L | 10/27/16 16:22 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-39
Lab ID: K1610283-039A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0052 | mg/L | 10/27/16 16:24 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-40
Lab ID: K1610283-040A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0066 | mg/L | 10/27/16 16:26 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-41
Lab ID: K1610283-041A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.032 * | mg/L | 10/27/16 16:32 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-42
Lab ID: K1610283-042A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0084 | mg/L | 10/27/16 16:34 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-43
Lab ID: K1610283-043A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0047 | mg/L | 10/27/16 16:36 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-44
Lab ID: K1610283-044A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.021 * | mg/L | 10/27/16 16:38 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - B Analyte detected in the associated Method Blank
 - E Value exceeds the instrument calibration range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below the PQL
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - P Prim./Conf. column %D or RPD exceeds limit
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-45
Lab ID: K1610283-045A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.46 * | mg/L | 10/27/16 16:39 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-46
Lab ID: K1610283-046A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.016 * | mg/L | 10/27/16 16:41 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-47
Lab ID: K1610283-047A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | < 0.0010 | mg/L | 10/27/16 16:43 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-48
Lab ID: K1610283-048A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.010 | mg/L | 10/27/16 16:45 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-49
Lab ID: K1610283-049A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.021 * | mg/L | 10/27/16 16:47 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-50
Lab ID: K1610283-050A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.37 * | mg/L | 10/27/16 16:49 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-51
Lab ID: K1610283-051A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0012 | mg/L | 10/27/16 16:58 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-52
Lab ID: K1610283-052A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.023 * | mg/L | 10/27/16 17:00 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-53
Lab ID: K1610283-053A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.048 * | mg/L | 10/27/16 17:02 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-54
Lab ID: K1610283-054A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.013 | mg/L | 10/27/16 17:04 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-55
Lab ID: K1610283-055A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0031 | mg/L | 10/27/16 17:06 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-56
Lab ID: K1610283-056A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.029 * | mg/L | 10/27/16 17:08 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-57
Lab ID: K1610283-057A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0012 | mg/L | 10/27/16 17:10 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-58
Lab ID: K1610283-058A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0011 | mg/L | 10/27/16 17:15 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-59
Lab ID: K1610283-059A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0012 | mg/L | 10/27/16 17:17 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-60
Lab ID: K1610283-060A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | < 0.0010 | mg/L | 10/27/16 17:19 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-61
Lab ID: K1610283-061A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0019 | mg/L | 10/27/16 17:21 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-62
Lab ID: K1610283-062A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0031 | mg/L | 10/27/16 17:23 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-63
Lab ID: K1610283-063A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0014 | mg/L | 10/27/16 17:25 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-64
Lab ID: K1610283-064A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0041 | mg/L | 10/27/16 17:27 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-65
Lab ID: K1610283-065A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0015 | mg/L | 10/27/16 17:29 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-66
Lab ID: K1610283-066A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.019 * | mg/L | 10/27/16 17:30 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - B Analyte detected in the associated Method Blank
 - E Value exceeds the instrument calibration range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below the PQL
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - P Prim./Conf. column %D or RPD exceeds limit
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-67
Lab ID: K1610283-067A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0020 | mg/L | 10/27/16 17:32 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-68
Lab ID: K1610283-068A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0011 | mg/L | 10/27/16 17:34 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-69
Lab ID: K1610283-069A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0014 | mg/L | 10/27/16 18:09 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-70
Lab ID: K1610283-070A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0017 | mg/L | 10/28/16 12:10 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-71
Lab ID: K1610283-071A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0012 | mg/L | 10/28/16 12:16 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-72
Lab ID: K1610283-072A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.051 * | mg/L | 10/28/16 12:17 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-73
Lab ID: K1610283-073A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.034 * | mg/L | 10/28/16 12:19 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-74
Lab ID: K1610283-074A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0013 | mg/L | 10/28/16 12:21 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-75
Lab ID: K1610283-075A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0013 | mg/L | 10/28/16 12:27 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-76
Lab ID: K1610283-076A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0013 | mg/L | 10/28/16 12:29 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-77
Lab ID: K1610283-077A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0084 | mg/L | 10/28/16 12:31 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-78
Lab ID: K1610283-078A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0029 | mg/L | 11/04/16 20:01 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-79
Lab ID: K1610283-079A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0013 | mg/L | 10/28/16 12:32 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-80
Lab ID: K1610283-080A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0084 | mg/L | 10/28/16 12:34 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-81
Lab ID: K1610283-081A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0061 | mg/L | 10/28/16 12:36 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-82
Lab ID: K1610283-082A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.16 * | mg/L | 11/14/16 13:27 |

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 1616376-Hammondsport Central School
Location: Lead Study
Matrix: PWS

Client Sample ID: HCS-83
Lab ID: K1610283-083A
Collection Date: 09/30/16 6:00
Date Received: 10/04/16 7:30

| Analyte | Result and Qualifiers | Units | Date Analyzed |
|------------------------|-----------------------|------------------|--------------------|
| METALS BY ICPMS | | EPA 200.8 | (EPA 200.2) |
| Lead | 0.0020 | mg/L | 10/28/16 12:38 |

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

Life Science Laboratories, Inc.

Sample Receipt Checklist

LSL LIMS

Project ID

1616376

Client ID: Invoiced_Government

Shipment Number 1

SRC Completed By: jms01

Date: 10/5/2016 3:06:18 PM


| COC Date/Time | Received By | Carrier | ShippingID |
|---|--------------------|--|-------------------|
| 10/4/2016 7:30:00 AM | jms01 | Hand Delivered | |
| Shipping container/cooler in good condition? | Yes | Sample containers intact? | Yes |
| Custody seal intact on shipping container/cooler? | N/A | Sufficient sample volume for indicated test? | Yes |
| Custody seals intact on sample bottles? | N/A | All samples received within holding time? | Yes |
| Chain of Custody present? | Yes | Container/Temp Blank temperature in compliance? | Yes |
| COC signed when relinquished and received? | Yes | Water - VOA vials have zero headspace? | N/A |
| COC agrees with sample labels? | Yes | Water - pH acceptable upon receipt? | N/A |
| Samples in proper containers/bottles? | Yes | Water - HNO ₃ added to unpreserved metal sample(s) to a pH of <2? | Yes |

Comments:

Corrective Action:

Reviewed By:

OK, 11/25/16



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

1616376

Invoiced Government

LSL Southern Tier Lab
30 E. Main St.
Cuba, NY 14727
p) 585-968-2640
f) 585-968-0906

LSL Midlakes Lab
699 S. Main St.
Canandaigua, NY 14424
p) 585-396-0270
f) 585-396-0377

LSL Finger Lakes Lab
16 N. Main St, PO Box 424
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL North Lab
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

200
R160283

Report Address:
Name: Hammondsport Central School
Company: 8272 Main St.
Street: Hammondsport, N.Y.
City/State: 607-569-5200
Phone: Koswien & h part. w.nyinc.org
Email: Client Project ID/Client Site ID

Zip: 14840
Fax: 607-569-5212

Turnaround Time
Normal 14 DAY 7-Day* 3-Day* 2-Day* 7-Day* *Additional Charges may apply

Date Needed or Special Instructions: Please Fax Lab Also fax: report to NYSDOH (Hornell) and e-mail School District

Authorization or P.O. # _____

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|---------------------------------------|----------|---------|
| | | | | | | # | size/type | | | |
| 1m 207 | 9/30/16 | 6:00 AM | Grab | PWS | HNU 3 | 1 | p250m | Lead | HCS-001A | 002A |
| 2nd FL girls RT | | | | | | | | | | 003A |
| H.S. Faculty RM | | | | | | | | | | 004A |
| 1m 234 RT | | | | | | | | | | 005A |
| RM 232 LFT | | | | | | | | | | 006A |
| 2nd FL Boys S. LFT | | | | | | | | Samples Preserved upon Receipt at Lab | | 007A |
| Girls 2nd FL S. LFT | | | | | | | | | | 008A |
| 1m 108 RT | | | | | | | | | | 009A |
| 2nd FL girls LFT | | | | | | | | | | 010A |
| 2nd FL 5 1/2 ft rest room | 9/30/16 | 6:00 AM | grab | PWS | | 1 | p250m | Lead | | |

LSL use only: _____


Custody Transfers

Sampled By: Ferry-Fairbrother Received By: _____
 Relinquished By: Maura Muller Received By: _____
 Relinquished By: Maura Muller Received By: _____

Rec'd for Lab By: JS
 Received Intact: Y N

Date: 10/4/16 Time: 7:30
 Sample Temp: 20.1

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
 Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

1616376
Invoiced_Government

LSL Central Lab 131 St. Lawrence Ave. Waddington, N.Y. 13694
 5854 Butternut Drive E. Syracuse, NY 13057
 p) 315-445-1105 f) 315-445-1301
 LSL Finger Lakes Lab 16 N. Main St, PO Box 424 Wayland, NY 14572
 LSL Midlakes Lab 699 S. Main St. Canandaigua, NY 14424
 LSL Southern Tier Lab 30 E. Main St. Cuba, NY 14727
 p) 585-728-3320 p) 585-968-2640
 f) 585-728-2711 f) 585-968-0906

200

Report Address:
 Name: Hammondsport Central School
 Company: 8272 Main St.
 Street: Hammondsport, N.Y.
 City/State: 827-569-5200
 Phone: Koswien & h part.wnynyc.org
 Email:

Zip: 14840
 Fax: 827-569-5212
Client Project ID/Client Site ID

Turnaround Time
 Normal 14 DAY 3-Day* 7-Day*
 Pre-authorized 2-Day* 3-Day* 7-Day*
 *Additional Charges may apply

Date Needed or Special Instructions: Please Fax Lab Also fax: report to NYSDOH (Hornell) and e-mail School District
Authorization or P.O. #


ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. Cl. | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|---------------------|----------|---------|
| | | | | | | # | size/type | | | |
| Km 234 LFT. | 9/30/16 | 6:00 AM | Grab | PWS | AN03 | 1 | p250m | Lead | H55 | 011A |
| Km 232 RT. | | | | | | | | | | 012A |
| Boys 2nd Fl. S. Rt. | | | | | | | | | | 013A |
| Girls 2nd Fl. S. Rt. | | | | | | | | | | 014A |
| 2nd Fl Boys Restroom LFT | | | | | | | | | | 015A |
| 2nd Fl Boys RT. | | | | | | | | Samples Preserved | | 016A |
| Km 203 | | | | | | | | Upon Receipt at Lab | | 017A |
| Km 106 | | | | | | | | | | 018A |
| Km 104 | | | | | | | | | | 019A |
| Km 108 center | 9/30/16 | 6:00 AM | grab | PWS | | 1 | p250m | Lead | | 020A |

LSL use only:
 Samples Received
 On Ice
 Containers this C-O-C: 10
 Shipment Method:
 Rec'd for Lab By: JS
 Received Intact: Y N
 Date: 10/4/16
 Sample Temp: 7.30
 Time: 20.1

Chain of Custody
 Sampled By: Ferry Fairbrother
 Relinquished By: Maura Mullen
 Relinquished By: Maura Mullen
 Received By: Maura Mullen
 Received By: Maura Mullen
 C-O-C: 10

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
 Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

1616376

Invoiced_Government

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St, PO Box 424
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Lab
699 S. Main St.
Canandaigua, NY 14424
p) 585-396-0270
f) 585-396-0377

LSL Southern Tier Lab
30 E. Main St.
Cuba, NY 14727
p) 585-968-2640
f) 585-968-0906

200

Report Address: Hammmondsport Central School
Name: _____
Company: _____
Street: 8272 Main St.
City/State: Hammmondsport, N.Y.
Phone: 607-569-5200
Email: Koswien@hpschool.wnyarc.org
Zip: 14840
Fax: 607-569-5212

Client Project ID/Client Site ID

Turnaround Time
 Normal 14 DAY
 Pre-Authorized Next Day* 3-Day* 7-Day*
 2-Day* 7-Day*

Date Needed or Special Instructions: Please Fax Lab
Also fax: report to NYSDOH (Hornell) and
e-mail School District
 Authorization or P.O. # _____


*Additional Charges may apply

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|---------------------|------|---------|
| | | | | | | # | size/type | | | |
| RM 108 LFT | 9/30/16 | 6:00 AM | Grab | PWS | HNO3 | 1 | p250m | Lead | OK | 021A |
| RM 110 Kystem | | | | | | | | | | 022A |
| RM 110 Kutechen | | | | | | | | | | 023A |
| RM 107 | | | | | | | | | | 024A |
| Library | | | | | | | | | | 025A |
| Girls Lib. restem LFT | | | | | | | | Samples Preserved | | 026A |
| Girls Lib. restem RT. | | | | | | | | Upon Receipt at Lab | | 027A |
| Boys restem Lib. RT. | | | | | | | | | | 028A |
| Girls Elem. restem center | | | | | | | | | | 029A |
| Girls Elem. restem 5 Bl. | 9/30/16 | 6:00 AM | Grab | PWS | | 1 | p250m | Lead | | 030A |

LSL use only:
 Samples Received _____
 On Ice _____
 Containers this C-O-C _____
 Shipment Method: _____
 Custody Transfers
 Received By: Ferry-Fairbrother Maurice Muller
 Relinquished By: Maurice Muller
 Relinquished By: Maurice Muller
 Rec'd for Lab By: JS
 Received Intact: Y N
 Date: _____
 Sample Temp: 7.50
20.1

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

1616376

Invoiced Government

200

LSL Central Lab 131 St. Lawrence Ave. Waddington, N.Y. 13694
 5854 Butternut Drive 16 N. Main St, PO Box 424 699 S. Main St.
 E. Syracuse, NY 13057 Waddington, N.Y. 14572 Canandaigua, NY 14424 Cuba, NY 14727
 p) 315-445-1105 p) 315-388-4476 p) 585-728-3320 p) 585-968-2640
 f) 315-445-1301 f) 315-388-4061 f) 585-728-2711 f) 585-396-0270 f) 585-968-0906

Report Address: Hammondsport Central School
Name: _____
Company: _____
Street: 8272 Main St.
City/State: Hammondsport, N.Y.
Phone: 607-569-5200
Email: Koswoc@hpsct.wnyric.org

Client Project ID/Client Site ID _____

Zip: 14840
Fax: 607-569-5212

Turnaround Time
 Normal 14 DAY 3-Day * 7-Day *
 Pre-Authorized 2-Day * 3-Day * 7-Day *
 *Additional Charges may apply

Date Needed or Special Instructions: Please Fax Lab Also fax: report to NYSDOH (Home) and e-mail School District
Authorization or P.O. # _____


ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. CA | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|---------------------------------------|---------|---------|
| | | | | | | # | size/type | | | |
| girls Elem restem S. LFT | 9/30/16 | 6:00 am | Grab | PWS | HN03 | 1 | p250m | Lead | HCS | 031A |
| Boys restem hb. LFT | | | | | | | | | | 032A |
| Boys Elem restem S. center | | | | | | | | | | 033A |
| Boys Elem restem S. RT | | | | | | | | | | 034A |
| LM 121 | | | | | | | | | | 035A |
| LM 122 | | | | | | | | | | 036A |
| LM 124 | | | | | | | | Samples Preserved Upon Receipt at Lab | | 037A |
| LM 126 | | | | | | | | | | 038A |
| LM 128 | | | | | | | | | | 039A |
| LM 130 | 9/30/16 | 6:00 AM | grab | PWS | | 1 | p250m | Lead | | 040A |

LSL use only: _____
 Samples Received _____
 On Ice _____
 Containers this C-O-C _____
 Shipment Method: _____
 Rec'd for Lab By: MS
 Received Intact: Y N
 Date: 19/11/16
 Sample Temp: 20.1

Received By: Ferry-Fairbrother Maurice Muller
Relinquished By: Maurice Muller
Relinquished By: _____

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
 Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

1616376

Invoiced_Government

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St, PO Box 424
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Lab
699 S. Main St.
Canandaigua, NY 14424
p) 585-396-0270
f) 585-396-0377

LSL Southern Tier Lab
30 E. Main St.
Cuba, NY 14727
p) 585-968-2640
f) 585-968-0906

Report Address:

Name: Hammondsport Central School
 Company: Hammondsport Central School
 Street: 8272 Main St.
 City/State: Hammondsport, N.Y.
 Phone: 607-569-5200
 Email: Kasweneh@act.wnyrc.org

Zip: 14840
 Fax: 607-569-5212

Client Project ID/Client Site ID

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.


| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|----------|------|---------|
| | | | | | | # | size/type | | | |
| Bay restem Eka S. et. | 9/30/16 | 6:00 AM | Grab | PWS | HNO3 | 1 | p250m | Lead | ✓ | 041A |
| Rm 120 | | | | | | | | | | 642A |
| Rm 118 restem | | | | | | | | | | 643A |
| Rm 117 Fountain | | | | | | | | | | 644A |
| Rm 118 Fountain | | | | | | | | | | 645A |
| Rm 119 | | | | | | | | | | 646A |
| Elem. Faculty Rm 56 | | | | | | | | | | 647A |
| Rm 111 | | | | | | | | | | 648A |
| Rm 112 | | | | | | | | | | 649A |
| Rm 118 Saveret | 9/30/16 | 6:00 AM | grab | PWS | | 1 | p250m | Lead | ✓ | 650A |

Samples Preserved Upon Receipt at Lab

Custody Transfers

Sampled By: Ferry Fairbrother Received By: Maurice Mullen
 Relinquished By: Maurice Mullen Received By: Maurice Mullen
 Relinquished By: Maurice Mullen
 Rec'd for Lab By: JS
 Received Intact: Y N
 Date: 10/4/16 Time: 7:30
 Sample Temp: 20.1

LSL use only: Containers this C-O-C
 Samples Received
 On Ice 10
 *** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
 Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc. CHAIN OF CUSTODY RECORD

1616376

Invoiced_Government

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St, PO Box 424
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Lab
699 S. Main St.
Canandaigua, NY 14424
p) 585-396-0270
f) 585-396-0377

LSL Southern Tier Lab
30 E. Main St.
Cuba, NY 14727
p) 585-968-2640
f) 585-968-0906

Report Address: Hammendsport Central School
Name: _____
Company: _____
Street: 8272 Main St.
City/State: Hammendsport, N.Y.
Phone: 607-569-5200
Email: Klawns@hport.wnyinc.org

Client Project ID/Client Site ID _____

Turnaround Time
 Normal 14 DAY 3-Day * 7-Day *
 Pre-Authorized 2-Day * 3-Day * 7-Day *
 *Additional Charges may apply

Date Needed or Special Instructions: Please Fax Lab Also fax: report to NYSDOH (Hornell) and e-mail School District
Authorization or P.O. # _____

| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. Ch | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|---------------------|---------|---------|
| | | | | | | # | size/type | | | |
| Boys Elem western LFT | 9/30/16 | 6:00 AM | Grab | PWS | None | 1 | p250m | Lead | ✓ | 051A |
| km 113 | | | | | | | | | | 052A |
| km 117 faucet | | | | | | | | | | 053A |
| Elem office | | | | | | | | Samples Preserved | | 054A |
| Elem- Staff western | | | | | | | | Upon Receipt at Lab | | 055A |
| km 114 | | | | | | | | | | 056A |
| Boys lounge RT | | | | | | | | | | 057A |
| Boys Elem eastern RT | | | | | | | | | | 058A |
| Boys lounge south- | | | | | | | | | | 059A |
| Boys lounge LFT. | 9/30/16 | 6:00 AM | grab | PWS | ✓ | 1 | p250m | Lead | ✓ | 060A |

Chain of Custody


Received By: _____
Relinquished By: Maurice Mulken
Relinquished By: Maurice Mulken
Rec'd for Lab By: SS
Received Intact: Y N

Shipments Method: _____
 Containers this C-O-C _____

On Ice **On Ice**

Date: 10/11/16
Time: 7:30
Sample Temp: 90.1

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
 Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc. CHAIN OF CUSTODY RECORD

1616376

Invoiced_Government

LSL Central Lab 5854 Butternut Drive LSL North Lab 131 St. Lawrence Ave. LSL Finger Lakes Lab 16 N. Main St, PO Box 424 LSL Midlakes Lab 699 S. Main St. LSL Southern Tier Lab 30 E. Main St.

E. Syracuse, NY 13057 Waddington, N.Y. 13694 Wayland, NY 14572 Canandaigua, NY 14424 Cuba, NY 14727

p) 315-445-1105 p) 315-388-4476 p) 585-728-3320 p) 585-396-0270 p) 585-968-2640

f) 315-445-1301 f) 315-388-4061 f) 585-728-2711 f) 585-396-0377 f) 585-968-0906

Report Address: Hammondsport Central School

Name: Hammondsport Central School

Company: Hammondsport Central School

Street: 8270 Main St.

City/State: Hammondsport, N.Y.

Phone: 607-569-5200

Email: K.baswer@hpschools.org

Client Project ID/Client Site ID

Zip: 14840

Fax: 607-569-5212

Turnaround Time

Normal 14 DAY Pre-Authorized Next Day* 3-Day* 7-Day*

Date Needed or Special Instructions: Please Fax Lab Also fax: report to NYSDOT (Hornell) and e-mail School District

Authorization or P.O. #

Additional Charges may apply

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. Ch | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|---------------------|---------|---------|
| | | | | | | # | size/type | | | |
| girls lounge restroom LFT | 9/29/16 | 6:00 am | Grab | PWS | HNO3 | 1 | p250m | Lead | MS- | 061A |
| girl's splay | | | | | | | | | | 062A |
| girls locker room LFT | | | | | | | | | | 063A |
| 1st Fl. N.S. staff restroom | | | | | | | | | | 064A |
| girls lounge restroom center | | | | | | | | Samples Preserved | | 065A |
| District office | | | | | | | | Upon receipt at Lab | | 066A |
| girls lounge restroom RT | | | | | | | | | | 067A |
| girls locker room RT | | | | | | | | | | 068A |
| girls Elem restroom LFT | 9/29/16 | 1:00 pm | grab | PWS | | 1 | p250m | Lead | | 069A |
| girls Elem restroom RT | | | | | | | | | | 070A |

Custody Transfers

Received By: Ferry-Fairbrother Marge Muller

Relinquished By: Melanie Muller

Relinquished By: Melanie Muller

Rec'd for Lab By: JS

Received Intact: Y N

Date: 10/4/16

Sample Temp: 7.50

LSL use only/Samples Received


On Ice

Containers this C-O-C

Shipment Method:

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***

Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

1616376

Invoiced_Government

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St, PO Box 424
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Southern Tier Lab
30 E. Main St.
Cuba, NY 14727
p) 585-968-2640
f) 585-968-0906

200

Report Address: Hammondsport Central School
Name: _____
Company: Hammondsport Central School
Street: 8272 Main St.
City/State: Hammondsport, N.Y.
Phone: (807-569-5200)
Email: Kasweneh@act.wnyinc.org

Client Project ID/Client Site ID _____

Zip: 14840
Fax: (807-569-5212)

| Client's Sample Identifications | Sample Date | Sample Time | Type grab/comp | Matrix | Preserv Added | Containers | | Analyses | Res. Ch | LSL ID# |
|---------------------------------|-------------|-------------|----------------|--------|---------------|------------|-----------|---------------------------------------|---------|---------|
| | | | | | | # | size/type | | | |
| Boys Locker RM RT. | 9/30/16 | 6:00 AM | Grab | PWS | HUO'S | 1 | p250m | Lead | HCS- | 671A |
| mainl. office | | | | | | | | | | 672A |
| Tech shop sink | | | | | | | | | | 673A |
| Boys Team RM RT. | | | | | | | | | | 674A |
| Girls Team RM | | | | | | | | Samples Preserved Upon receipt at Lab | | 675A |
| All-gender RT | | | | | | | | | | 676A |
| RM 93C | | | | | | | | | | 677A |
| ice maker | | | | | | | | | | 078A |
| girls couch off. | | | | | | | | | | 679A |
| Boy Couch off. | 9/30/16 | 6:00 AM | grab | PWS | | 1 | p250m | Lead | | 080A |

Turnaround Time
Normal 14 DAY
Pre-Authorized
 Next Day* 2-Day* 3-Day* 7-Day*
 *Additional Charges may apply

Date Needed or Special Instructions: please Fax Lab Also fax: report to NYSDOH/Chemicals and e-mail School District
Authorization or P.O. # _____

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

Custody Transfers

Received By: Ferry-Fairbrother Maurice Muller
Relinquished By: Maurice Muller
Rec'd for Lab By: JS
Received Intact: Y N

Date: 10/11/16
Time: 7:30
Sample Temp: 20.1

LSL use only:
 Samples Received _____
 On Ice _____
 Containers this C-O-C _____

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
 Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.

