

<b>Hammondspport Central School</b>						
<b>Nov-16</b>						
<b>Lead Testing Results</b>		<b>Locations with Action Levels Reported: State Action Level is .015 or above</b>			<b>Sitting Draw</b>	<b>Flush Draw</b>
<b>Location</b>	<b>Level</b>	<b>Remediation</b>	<b>Retest Results from 1/26/2017</b>	<b>Retest Results from 3/10/2017 1st draw</b>	<b>Retest Results from 3/10/2017 2nd draw</b>	<b>New Remediation</b>
Sink room 112	0.021	Cold Water Shut Off, Signage Posted, Retesting.		0.017	0.0045	Must be fixture/Replace asap.
Sink room 113	0.023	Cold Water Shut Off, Signage Posted, Retesting.	0.017	0.03	0.0018	Must be fixture/Replace asap.
Sink room 114	0.029	Cold Water Shut Off, Signage Posted, Retesting.	0.031	0.28	0.0027	Must be fixture/Replace asap.
Sink room 117	0.048	Cold Water Shut Off, Signage Posted, Retesting.	0.018	0.015	0.0014	Must be fixture/Replace asap.
Fountain room 117	0.021	Water shut off. Engineer is being brought in to review options.	0.0053	0.004	0.0015	CLEAR- remove signage
Sink room 118	0.37	Cold Water Shut Off, Signage Posted, Retesting.	0.077	0.076	0.0055	Must be fixture/Replace asap.
Fountain room 118	0.46	Water shut off. Engineer is being brought in to review options.	0.097	0.028	0.0026	Must be fixture/Replace asap.
Sink room 119	0.16	Cold Water Shut Off, Signage Posted, Retesting.		0.014	0.0018	CLEAR- remove signage
Sink room 121	0.021	Cold Water Shut Off, Signage Posted, Retesting.	0.013			
Sink room 122	0.017	Cold Water Shut Off, Signage Posted, Retesting.	0.035	0.0052	0.0019	CLEAR- remove signage
Sink room 124	0.026	Cold Water Shut Off, Signage Posted, Retesting.	0.12	0.029	0.002	Must be fixture/Replace asap.
Sink room 126	0.015	Cold Water Shut Off, Signage Posted, Retesting.	0.022	0.028	0.002	Must be fixture/Replace asap.
Sinks in boys 4th/5th grade bathroom	.032RT/	Cold Water Shut Off, Signage Posted, Retesting.	0.0089			CLEAR- remove signage
Sink in room 104	0.085	Water turned off. Sink is being removed.				NA
Sink in room 106	0.058	Water turned off. Sink is being removed.				NA
Sink in room 107	0.029	Water turned off. Sink is being removed.				NA
District Office sink	0.019	Cold Water Shut Off, Signage Posted, Retesting.				
Tech shop sink	0.034	Cold Water Shut Off, Signage Posted, Retesting.				
Maintenance area bathroom sink	0.051	Cold Water Shut Off, Signage Posted, Retesting.		0.063	0.0089	Leave signage up, must be fixture but never used for drinking.
Kitchen wall tap near steamer	0.16	Signage posted. Y fitting will be removed and retesting done.	0.012			CLEAR- remove signage
<b>2nd Floor</b>						
Sinks in 6/7 boys bathroom	.02LFT/	Cold Water Shut Off, Signage Posted, Retesting.	0.021			
Sinks in HS wing boys bathroom	0.015LFT/	Cold Water Shut Off, Signage Posted, Retesting.	0.0082			
Sinks in HS wing girls bathroom	0.038LFT/0.052RT	Cold Water Shut Off, Signage Posted, Retesting.	0.11			
Sink in room 232	.024LFT/.046RT	Cold Water Shut Off, Signage Posted, Retesting.	.053LFT.015RT			
Sinks in room 234	.015RT/	Cold Water Shut Off, Signage Posted, Retesting.	.014RT/.015LFT			
Sinks in room 207	0.1	Cold Water Shut Off, Signage Posted, Retesting.				