



# Life Science Laboratories, Inc.

---

Hammondsport Central School  
8272 Main St.  
Hammondsport, NY 14840

Phone: (607) 569-5200  
FAX: (607) 569-5212

## Laboratory Analysis Report

### Prepared For

## Hammondsport Central School

LSL Project ID: 1605936

Receive Date/Time: 04/27/16 9:40

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab  
5854 Butternut Drive  
East Syracuse, NY 13057  
Tel. (315) 445-1900  
Fax (315) 445-1104  
NYS DOH ELAP #10248  
PA DEP #68-2556

LSL North Lab  
131 St. Lawrence Avenue  
Waddington, NY 13694  
Tel. (315) 388-4476  
Fax (315) 388-4061  
NYS DOH ELAP #10900

LSL Finger Lakes Lab  
16 N. Main St., PO Box 424  
Wayland, NY 14572  
Tel. (585) 728-3320  
Fax (585) 728-2711  
NYS DOH ELAP #11667

LSL Southern Tier Office  
Cuba, NY  
Tel. (585) 209-4032

LSL MidLakes Office  
Canandaigua, NY  
Tel. (585) 728-3320

Reviewed by:

Date:

5/11/16

David J. Prichard, Director of Tech. Services

A copy of this report was sent to:

**- - LABORATORY ANALYSIS REPORT - -**

*Hammondsport Central School Hammondsport, NY*

Sample ID: Rm 117 LSL Sample ID: 1605936-001

Location:

Sampled: 04/27/16 7:33 Sampled By: MM

Sample Matrix: PWS

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
-------------------	--------	-------	-------------	-----------	----------------------	------------------

(1) EPA 200.8 Metals

EPA 200.2

MT

Please refer to the next page

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1605936-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 117*  
**Lab ID:** **K1605065-001A**  
**Collection Date:** 04/27/16 7:33  
**Date Received:** 04/27/16 9:40

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.031 *	mg/L	05/09/16 18:58

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits

**-- LABORATORY ANALYSIS REPORT --**

*Hammondsport Central School Hammondsport, NY*

Sample ID: Rm 118 LSL Sample ID: 1605936-002

Location:

Sampled: 04/27/16 7:32 Sampled By: MM

Sample Matrix: PWS

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
-------------------	--------	-------	-------------	-----------	----------------------	------------------

(1) EPA 200.8 Metals

EPA 200.2

Please refer to the next page

MT

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1605936-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 118*  
**Lab ID:** **K1605065-002A**  
**Collection Date:** 04/27/16 7:32  
**Date Received:** 04/27/16 9:40

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.016 *	mg/L	05/09/16 19:01

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**-- LABORATORY ANALYSIS REPORT --**

*Hammondsport Central School Hammondsport, NY*

Sample ID: Elem. Rest Rm. Hallway LSL Sample ID: 1605936-003

Location:

Sampled: 04/27/16 7:35 Sampled By: MM

Sample Matrix: PWS

Analytical Method	Result	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Units				

(1) EPA 200.8 Metals

EPA 200.2

MT

Please refer to the next page

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1605936-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Elem. Restr. Hallway*

**Lab ID:** **K1605065-003A**  
**Collection Date:** 04/27/16 7:35  
**Date Received:** 04/27/16 9:40

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.015 *	mg/L	05/09/16 19:05

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





