



# Life Science Laboratories, Inc.

Date Printed:

4/19/16

## Laboratory Analysis Report For Hammondsport Central School

LSL Project ID: 1604323

Hammondsport Central School  
8272 Main St.  
Hammondsport, NY 14840

Phone: (607) 569-5200  
FAX: (607) 569-5212

*A copy of this report was sent to:*

Sample ID: Lead Study  
Location:  
Sampled: 03/30/16 7:35  
Sampled By: MM

LSL Sample ID: 1604323-001  
Receive Date/Time: 03/30/16 9:15  
Project Rec'd by: ds02

Matrix: PW

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			
(1) Lead Study				
Number of Samples	27			MT

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab  
5854 Butternut Drive  
East Syracuse, NY 13057  
Tel. (315) 445-1900  
Fax (315) 445-1104  
NYS DOH ELAP #10248  
PA DEP #68-2556

LSL North Lab  
131 St. Lawrence Avenue  
Waddington, NY 13694  
Tel. (315) 388-4476  
Fax (315) 388-4061  
NYS DOH ELAP #10900

LSL Finger Lakes Lab  
16 N. Main St., PO Box 424  
Wayland, NY 14572  
Tel. (585) 728-3320  
Fax (585) 728-2711  
NYS DOH ELAP #11667

LSL Southern Tier Office  
Cuba, NY  
Tel. (585) 209-4032  
  
LSL MidLakes Office  
Canandaigua, NY  
Tel. (585) 728-3320

Reviewed by:

David J. Prichard, Director of Tech. Services

Date:

4/20/16

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 115*  
**Lab ID:** **K1604141-001A**  
**Collection Date:** 03/30/16 7:35  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0082	mg/L	04/15/16 19:09

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 119*

**Lab ID:** **K1604141-002A**  
**Collection Date:** 03/30/16 7:40  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0071	EPA 200.8 mg/L	04/15/16 19:13

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 128*  
**Lab ID:** **K1604141-003A**  
**Collection Date:** 03/30/16 7:47  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0025	mg/L	04/15/16 19:17

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *High School Hallway*

**Lab ID:** K1604141-004A  
**Collection Date:** 03/30/16 7:55  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0062	mg/L	04/15/16 19:21

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Library Lobby*

**Lab ID:** **K1604141-005A**  
**Collection Date:** 03/30/16 7:51  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	< 0.0010	mg/L	04/15/16 19:25

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 124*  
**Lab ID:** **K1604141-006A**  
**Collection Date:** 03/30/16 7:45  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0051	mg/L	04/15/16 19:37

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Jr High Hallway*  
**Lab ID:** **K1604141-007A**  
**Collection Date:** 03/30/16 7:57  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0016	mg/L	04/15/16 19:41

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**

5854 Butternut Drive  
East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 120*  
**Lab ID:** **K1604141-008A**  
**Collection Date:** 03/30/16 7:41  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0050	mg/L	04/15/16 19:44

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 121*

**Lab ID:** **K1604141-009A**  
**Collection Date:** 03/30/16 7:42  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0051	mg/L	04/15/16 19:48

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



# Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Hallway Cafeteria*

**Lab ID:** **K1604141-010A**  
**Collection Date:** 03/30/16 7:21  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0013	EPA 200.8 mg/L	04/15/16 19:52

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 117*

**Lab ID:** **K1604141-011A**  
**Collection Date:** 03/30/16 7:35  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.020 *	mg/L	04/15/16 19:56

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 116*

**Lab ID:** **K1604141-012A**  
**Collection Date:** 03/30/16 7:34  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0016	mg/L	04/15/16 20:00

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 126*  
**Lab ID:** **K1604141-013A**  
**Collection Date:** 03/30/16 7:44  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0075	EPA 200.8 mg/L	04/15/16 20:03

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Girls Side Gym*

**Lab ID:** **K1604141-014A**  
**Collection Date:** 03/30/16 7:20  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0012	mg/L	04/15/16 20:07

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 118*  
**Lab ID:** **K1604141-015A**  
**Collection Date:** 03/30/16 7:39  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.016 *	mg/L	04/15/16 20:11

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Elem Restroom Hallway*

**Lab ID:** **K1604141-016A**  
**Collection Date:** 03/30/16 7:48  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.020 *	mg/L	04/15/16 20:23

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 113*  
**Lab ID:** **K1604141-017A**  
**Collection Date:** 03/30/16 7:34  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.011	mg/L	04/15/16 20:27

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 106*  
**Lab ID:** **K1604141-018A**  
**Collection Date:** 03/30/16 7:53  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0055	mg/L	04/15/16 20:31

**Qualifiers:**

* Value may exceed the Acceptable Level	B Analyte detected in the associated Method Blank
E Value exceeds the instrument calibration range	H Holding times for preparation or analysis exceeded
J Analyte detected below the PQL	ND Not Detected at the Practical Quantitation Limit (PQL)
P Prim./Conf. column %D or RPD exceeds limit	S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Kitchen*

**Lab ID:** K1604141-019A  
**Collection Date:** 03/30/16 7:10  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	< 0.0010	mg/L	04/15/16 20:35

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Entry Point*

**Lab ID:** K1604141-020A  
**Collection Date:** 03/30/16 7:15  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0081	mg/L	04/17/16 10:02

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Elem Lobby*

**Lab ID:** **K1604141-021A**  
**Collection Date:** 03/30/16 7:26  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0077	mg/L	04/17/16 10:13

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 112*  
**Lab ID:** **K1604141-022A**  
**Collection Date:** 03/30/16 7:31  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.012	mg/L	04/17/16 10:17

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 114*  
**Lab ID:** **K1604141-023A**  
**Collection Date:** 03/30/16 7:32  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.013	mg/L	04/17/16 10:20

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Rm 111*  
**Lab ID:** **K1604141-024A**  
**Collection Date:** 03/30/16 7:29  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	0.0058	mg/L	04/17/16 10:24

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Elem Gym*  
**Lab ID:** **K1604141-025A**  
**Collection Date:** 03/30/16 7:27  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	< 0.0010	mg/L	04/17/16 10:28

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** Lounge Student

**Lab ID:** K1604141-026A  
**Collection Date:** 03/30/16 7:24  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	< 0.0010	mg/L	04/17/16 10:40

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1604323-Hammondsport Central School  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** *Boys Side Gym*

**Lab ID:** **K1604141-027A**  
**Collection Date:** 03/30/16 7:19  
**Date Received:** 03/30/16 9:15

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	
Lead	< 0.0010	mg/L	04/17/16 10:44

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



# Life Science Laboratories, Inc.

## CHAIN OF CUSTODY RECORD

1604323

Invoiced Government  
Ribeiro 200

LSL Central Lab  
5854 Butternut Drive  
Syracuse, NY 13057  
p) 315-445-1105  
f) 315-445-1301

LSL Finger Lakes Lab  
16 N. Main St, PO Box 424  
Wayland, NY 14572  
p) 585-728-3320  
f) 585-728-2711

LSL Southern Tier Office  
24 W. Main St.  
Cuba, NY 14727  
p) 585-209-4032  
Office # 2

or 585-704-6973

**SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERING TO LAB**

Report Address:  
Name: Hammondsport Central School  
Company: Hammondsport Central School  
Street: 8072 Main St. Zip: 14840  
City/State: Hammondsport, N.Y.  
Phone: 607-569-5200 Fax: 607-569-5212  
Email: Kbowser@hpc.sny.net  
Client Project ID/Client Site ID

Turnaround Time  
Normal  Pre-Authorized   
14 DAY  Next Day\*  3-Day\*   
2-Day\*  7-Day\*   
\*Additional Charges may apply

Date Needed or Special Instructions: Please FAX or e-mail Lab report to School District

Payment, Authorization or P.O. #

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
Rm 115	3/30/16	7:55 AM	gr2b	DW	None	1	gr2b	Pb	✓	002A
Rm 119	3/30/16	7:40 AM	gr2b	DW				Pb		002A
Rm 128	3/30/16	7:47 AM	gr2b	DW				Pb		003A
High School Hallway	3/30/16	7:55 AM	gr2b	DW				Pb		004A
Library Lobby	3/30/16	7:57 AM	gr2b	DW				Pb		005A
Rm 124	3/30/16	7:45 AM	gr2b	DW				Pb		006A
Jr High Hallway	3/30/16	7:51 AM	gr2b	DW				Pb		007A
Rm 120	3/30/16	7:41 AM	gr2b	DW				Pb		008A
Rm 121	3/30/16	7:42 AM	gr2b	DW				Pb		009A

LSL use only.

9 of 21

Samples Present: 9  
 Upon Receipt at: LSL  
 Relinquished By: Maurice Mullen  
 Relinquished By: Maurice Mullen  
 Shipment Method: Hand  
 Containers this C-O-C: 9  
 Rec'd for Lab By: MS  
 Received Intact: Y N  
 Sample Temp: 9.15 °C

\*\*\* All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY\*\*\*  
 Nitrates & Nitrites must be received before 2:30 pm Mon.-Thur. And taken just before being brought in to the lab.

Samples Received  
On Ice



# Life Science Laboratories, Inc.

## CHAIN OF CUSTODY RECORD

1604323

Invoiced Government

LSL Central Lab  
5854 Butternut Drive  
Syracuse, NY 13057  
p) 315-445-1105  
f) 315-445-1301

LSL Finger Lakes Lab  
16 N. Main St, PO Box 424  
Wayland, NY 14572  
p) 585-728-3320  
f) 585-728-2711

LSL Midlakes Office  
493 S. Main St.  
Canandaigua, NY 14424  
p) 585-728-3320  
f) 585-728-2711

LSL Southern Tier Office  
24 W. Main St.  
Cuba, NY 14727  
p) 585-209-4032  
Office # 2

or 585-704-6973

### SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERING TO LAB

Report Address: Hammondsport Central School

Name: Hammondsport Central School

Company: Hammondsport Central School

Street: 8072 Main St.

City/State: Hammondsport, N.Y.

Phone: 607-569-5200

Email: K.bower@hpsd.net

Zip: 14840

Fax: 607-569-5202

Client Project ID/Client Site ID: anytrk.org

Turnaround Time

Normal  14 DAY

Pre-Authorized  Next Day\*  2-Day\*  3-Day\*  7-Day\*

\*Additional Charges may apply

Date Needed or Special Instructions: Please FAX or e-mail Lab report to School District

Payment, Authorization or P.O. #

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
Hammondsport Central School	3/30/16	7:21 AM	gr2b	DW	4003	1	gr2b	Pb	✓	010A
Rm 117	3/30/16	7:35 AM	gr2b	DW				Pb	✓	011A
Rm 116	3/30/16	7:34 AM	gr2b	DW				Pb	✓	012A
Rm 126	3/30/16	7:44 AM	gr2b	DW				Pb	✓	013A
Girls Side Gym	3/30/16	7:20 AM	gr2b	DW				Pb	✓	014A
Rm 118	3/30/16	7:39 AM	gr2b	DW				Pb	✓	015A
Elem Restroom hallway	3/30/16	7:45 AM	gr2b	DW				Pb	✓	016A
Rm 113	3/30/16	7:47 AM	gr2b	DW				Pb	✓	017A
Rm 106	3/30/16	7:53 AM	gr2b	DW				Pb	✓	018A

LSL use only:

Samples Preserved  Upon Receipt at Lab

Custody Transfers

Received By: Maurice Mullen

Relinquished By: Maurice Mullen

Relinquished By: Maurice Mullen

Rec'd for Lab By: MS

Received Intact: Y N

Date: 3-30-16

Time: 9:15

Sample Temp: 18°C

909 27 Containers this C-O-C

\*\*\* All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY\*\*\*

Nitrates & Nitrites must be received before 2:30 pm Mon.-Thur. And taken just before being brought in to the lab.

Samples Received

On Ice



# Life Science Laboratories, Inc.

## CHAIN OF CUSTODY RECORD

1604323

Invoiced Government

LSL Central Lab 5854 Butternut Drive E. Syracuse, NY 13057 p) 315-445-1105 f) 315-445-1301  
 LSL North Lab 131 St. Lawrence Ave. Waddington, N.Y. 13694 p) 315-388-4476 f) 315-388-4061  
 LSL Finger Lakes Lab 16 N. Main St, PO Box 424 Wayland, NY 14572 p) 585-728-3320 f) 585-728-2711  
 LSL Midlakes Office 493 S. Main St. Canandaigua, NY 14424 p) 585-728-3320 f) 585-728-2711  
 LSL Southern Tier Office 24 W. Main St. Cuba, NY 14727 p) 585-209-4032 Office # 2

or 585-704-6973  
**SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERING TO LAB**

Report Address: Hammondsport Central School  
 Name: Hammondsport Central School  
 Company: Hammondsport Central School  
 Street: 8070 Main St.  
 City/State: Hammondsport, N.Y.  
 Phone: 607-569-5200  
 Email: K.bower@nport.wnybc.org  
 Client Project ID/Client Site ID: \_\_\_\_\_  
 Zip: 14840  
 Fax: 607-569-5212

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
Kitchen	3/30/16	710 AM	gr2b	Duo	HAAS	1	P124	Pb	✓	019A
entry point	3/30/16	715 AM	gr2b	Duo		↓	↓	Pb	✓	020A
Elem Lobby	3/30/16	726 AM	gr2b	Duo				Pb	✓	021A
Rm 112	3/30/16	731 AM	gr2b	Duo				Pb	✓	022A
Rm 114	3/30/16	732 AM	gr2b	Duo				Pb	✓	023A
Rm 111	3/30/16	739 AM	gr2b	Duo				Pb	✓	024A
Elem Gym	3/30/16	727 AM	gr2b	Duo				Pb	✓	025A
Lounge Student	3/30/16	727 AM	gr2b	Duo				Pb	✓	026A
Boys Side Gym	3/30/16	719 AM	gr2b	Duo				Pb	✓	027A

Turnaround Time:  Normal  Pre-Authorized  3-Day\*  7-Day\*  
 \*Additional Charges may apply

Date Needed or Special Instructions: Please FAX or e-mail Lab report to School District

Payment, Authorization or P.O. # \_\_\_\_\_

Received By: Maurice Mullen  
 Relinquished By: Maurice Mullen  
 Rec'd for Lab By: DS  
 Received Intact: Y N

Sample Temp: 18°C

9 of 27

LSL use only: Samples Preserved Upon Receipt at Lab Containers this C-O-C

\*\*\* All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY\*\*\*

Nitrates & Nitrites must be received before 2:30 pm Mon.-Thur. And taken just before being brought in to the lab.

Samples Received On Ice